

SAFETY, STRUCTURES AND FIRE DEPARTMENT

Reaction to Fire

REACTION TO FIRE CLASSIFICATION REPORT No. RA15-0217 ACCORDING TO THE EUROPEAN STANDARD NF EN 13501-1+A1:2013

Notification by the French Government to the European Commission under no. 0679
Seule la version française fait foi
The French version is legally acceptable

Product standard

NF EN 14716:2005 "Stretched ceilings - Requirements and test methods"

Owner: SERGE FERRARI

Zone Industrielle

38110 LA TOUR DU PIN

FRANCE

Commercial brand(s): PRECONTRAINT 502

Manufacturing unit(s): The manufacturing unit appears in the associated tests report

Brief description: Coated fabric for a textile architecture and a stretched ceiling

application

(see detailed description in paragraph 2)

Date of issue: July 28th, 2016

This classification report certifies only the characteristics of the object submitted for testing but does not prejudge the characteristics of similar products. So it does not constitute a product certification in the sense of Articles L 115-27 to L 115-33 and R 115-1 to R 115-3 of the Consumer Code.

If this report is being issued by e-mail and/or on an electronic medium, only the hard copy of the report signed by CSTB shall prevail in the event of a dispute.

The reproduction of this classification report is only authorised in its integral form. It comprises 4 pages.

Update of the document RA15-0217 dated September 16th, 2015. The document RA15-0217 dated July 28th, 2016 cancels and replaces the document RA15-0217 dated September 16th, 2015.



1. Introduction

This classification report defines the classification assigned to the above-mentioned product(s) in accordance with the procedures given in the NF EN 13501-1+A1:2013 standard.

2. Product description

Coated fabric for a textile architecture and a stretched ceiling application. Fabric consisting of a 100 % polyester fibres backing coated on both sides with fire retarded polyvinyl chloride.

Overall nominal thickness: $0.47 \text{ mm} \pm 10 \%$.

Overall nominal weight per unit area: 590 g/m² \pm 5 %.

Nominal weight per unit area of the polyester mesh: $165 \text{ g/m}^2 \pm 10 \%$.

Colours: various.



3. Tests reports and tests results in support of this classification

3.1 Tests reports

Name of laboratory	Name of sponsor	Test identification	Test report No.	Test method
СЅТВ	SERGE FERRARI Zone Industrielle	ES541160362 Modification		-
	38110 LA TOUR DU PIN FRANCE	ES541150384	RA15-0217	NF EN ISO 11925-2:2013 NF EN 13823+A1:2015

3.2 Tests results

Test method	Product	Number of tests	Parameters	Results Compliance parameters
NF EN ISO 11925-2 30s surface exposure	PRECONTRAINT 502	6	Fs > 150 mm Filter paper	Not reached Not ignited
NF EN ISO 11925-2 30s edge exposure	PRECONTRAINT 502	6	Fs > 150 mm Filter paper	Not reached Not ignited

				Results		
Test method	Product	Product Number of tests Parameters	Parameters	Continuous parameters Mean values	Compliance parameters	
NF EN 13823	PRECONTRAINT 502	3	FIGRA _{0.2MJ} (W/s) FIGRA _{0.4MJ} (W/s) LFS THR _{600s} (MJ)	21.4 0.0 - 0.7	- - Not reached -	
			SMOGRA(m²/s²) TSP _{600s} (m²)	65.3 85.7	- -	
			Flaming droplets or debris	-	None	

⁽⁻⁾ means: not applicable



4. Classification and direct field of application

4.1 Reference of the classification

This classification has been carried out in accordance with clauses 11.6, 11.9.3 and 11.10.1 of the NF EN 13501-1+A1:2013 standard.

4.2 Classification

Fire behaviour		Smoke production		Flaming droplets or debris
В	-	s2	,	d0

Classification: B - s2, d0

4.3 Field of application

This classification is valid for the following product parameters:

- The product described in paragraph 2.
- An overall nominal thickness of 0.47 mm \pm 10 %.
- An overall nominal weight per unit area of 590 g/m $^2 \pm 5$ %.
- A nominal weight per unit area of the polyester mesh of 165 g/m 2 ± 10 %.
- Various colours.

This classification is valid for the following end use conditions:

- Without substrate or with any A1 or A2-s1,d0 class substrate with a density \geq 652 kg/m³ and with a thickness \geq 9 mm.
- With a minimum air gap of 80 mm.

5. Limitation

The present document does not represent type approval or certification of the product.

Champs-sur-Marne, July 28th, 2016

The Report Writer

Benoit FOREST

The Head of Reaction to Fire Unit

Gildas CREACH

......END OF THE CLASSIFICATION REPORT